

ATTESTATION OF CONFORMITY

Issued to: HANTECH IKLIMLENDİRME SAN.TIC.A.S.
Ziya Gökalp Mah. Süleyman Demirel Blv. No:138 7-E, Başakşehir İstanbul, Türkiye

For the product: Split-Type Air-Conditioner

Trade name: HANTECH

Type/Model: Indoor unit / outdoor unit:
HNT-F24VMTC/I / HNT-F24VMTC/O

Ratings: 220-240 V~, 50 Hz, Class I

Manufactured by: TCL Air conditioner (Zhong Shan) Co., Ltd.
No. 59, Nantou Road West, Nantou, Zhongshan, Guangdong, China

Requirements: EN 55014-1:2017 + A11:2020 EN 55014-2:2015
EN IEC 55014-1:2021 EN IEC 55014-2:2021
EN IEC 61000-3-2:2019 + A1:2021 EN 61000-3-3:2013 + A1:2019

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 4398601.50.

This Attestation implies that the examined types are in accordance with the standards designated under the Electromagnetic Compatibility Directive (EMC) 2014/30/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Arnhem, 13 January 2023

Number: 4398601.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.,
Guangzhou Branch



Rosa Zhou
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing and Certification (Shanghai) Ltd., Guangzhou Branch
Block 5, No.3, Qiyun Road, Huangpu District, Guangzhou, Guangdong, China
T +86 20 6661 2000 F +86 20 6661 2001 www.dekra-product-safety.com

