

# Model name

## A12FT UL2 (Outdoor unit) / A12FT NSF (Indoor unit)

Function (Indicate if present)		If the function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.	
cooling	Y	Average (mandatory)	Y
heating	Y	Warmer (if designated)	Y
		Colder (if designated)	N
Declared capacity* for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj		Declared Energy efficiency ratio* for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj	
Tj=35°C	Pdc 3,50 kW	Tj=35°C	EERd 3,33
Tj=30°C	Pdc 2,58 kW	Tj=30°C	EERd 5,13
Tj=25°C	Pdc 1,66 kW	Tj=25°C	EERd 7,94
Tj=20°C	Pdc 1,04 kW	Tj=20°C	EERd 12,40
Declared capacity* for heating / Average climate, at indoor temperature 20°C and outdoor temperature Td		Declared Coefficient of performance* for heating / Average climate, at indoor temperature 20°C and outdoor temperature Tj	
Tj=-7°C	Pdh 2,39 kW	Tj=-7°C	COPd 2,80
Tj=2°C	Pdh 1,46 kW	Tj=2°C	COPd 4,15
Tj=7°C	Pdh 0,98 kW	Tj=7°C	COPd 4,50
Tj=12°C	Pdh 1,10 kW	Tj=12°C	COPd 6,00
Tj=bivalent temperature	Pdh 2,70 kW	Tj=bivalent temperature	COPd 2,45
Tj=operating limit	Pdh 2,70 kW	Tj=operating limit	COPd 2,45
Declared capacity* for heating / Warmer climate, at indoor temperature 20°C and outdoor temperature Tj		Declared Coefficient of performance* / Warmer climate, at indoor temperature 20°C and outdoor temperature Tj	
Tj=2°C	Pdh 1,50 kW	Tj=2°C	COPd 4,09
Tj=7°C	Pdh 0,98 kW	Tj=7°C	COPd 4,50
Tj=12°C	Pdh 1,10 kW	Tj=12°C	COPd 6,00
Tj=bivalent temperature	Pdh 1,50 kW	Tj=bivalent temperature	COPd 4,09
Tj=operating limit	Pdh 1,50 kW	Tj=operating limit	COPd 4,09
Declared capacity* for heating / Colder climate, at indoor temperature 20°C and outdoor temperature Tj		Declared Coefficient of performance* / Colder climate, at indoor temperature 20°C and outdoor temperature Tj	
Tj=-7°C	Pdh x,x kW	Tj=-7°C	COPd x,x
Tj=2°C	Pdh x,x kW	Tj=2°C	COPd x,x
Tj=7°C	Pdh x,x kW	Tj=7°C	COPd x,x
Tj=12°C	Pdh x,x kW	Tj=12°C	COPd x,x
Tj=bivalent temperature	Pdh x,x kW	Tj=bivalent temperature	COPd x,x
Tj=operating limit	Pdh x,x kW	Tj=operating limit	COPd x,x
Tj=-15°C	Pdh x,x kW	Tj=-15°C	COPd x,x
Design load		Seasonal efficiency	
cooling	Pdesignc 3,5 kW	cooling	SEER 6,6
heating / Average	Pdesignh 2,7 kW	heating / Average	SCOPIA 4,0
heating / Warmer	Pdesignh 1,5 kW	heating / Warmer	SCOPW 4,6
heating / Colder	Pdesignh x,x kW	heating / Colder	SCOPIC x,x
Bivalent temperature		Operating limit temperature	
heating / Average	Tbiv -10 °C	heating / Average	Tol -10 °C
heating / Warmer	Tbiv 2 °C	heating / Warmer	Tol 2 °C
heating / Colder	Tbiv x °C	heating / Colder	Tol x °C
Cycling interval capacity		Cycling interval efficiency	
for cooling	Pcycc x,x kW	for cooling	EERcyc x,x
for heating	Pcyhc x,x kW	for heating	COPcyc x,x
Degradation co-efficient cooling**		Degradation co-efficient heating**	
Cdc	0,25	Cdh	0,25
Electric power input in power modes other than 'active mode'		Annual electricity consumption	
off mode	P <sub>OFF</sub> 0,003 kW	cooling	Q <sub>CE</sub> 186 kWh/a
standby mode	P <sub>SB</sub> 0,003 kW	heating / Average	Q <sub>HE</sub> 945 kWh/a
thermostat-off mode	P <sub>TO</sub> 0,02 kW	heating / Warmer	Q <sub>HE</sub> 457 kWh/a
crankcase heater mode	P <sub>CK</sub> 0 kW	heating / Colder	Q <sub>HE</sub> x,x kWh/a
Capacity control (indicate one of three options)		Other items	
fixed	N	Sound power level (indoor/outdoor)	L <sub>WA</sub> 60 / 65 dB(A)
staged	N	Global warming potential	GWP 675 kgCO <sub>2</sub> eq.
variable	Y	Rated air flow (indoor/outdoor)	600 / 2100 m <sup>3</sup> /h
Contact details for obtaining more information		Christianna PAPAZHARIOU Internal communicator - Energy & environment regulations expert LG Electronics Paris Nord II - 117 avenue des Nations BP 59372 Villepinte - 95942 Roissy CDG Cedex chris.papazahariou@lge.com Tel. +33 1 49 89 57 41, +33 6 83 077 455	

\*= For staged capacity units, two values divided by a slash (/) will be declared in each box in the section "Declared capacity of the unit" and "declared EER/COP" of the unit.

\*\*= If default Cd=0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.

