Information to identify the model(s) to which the information relates to:			If function includes heating: Indicate the heat	ing season th	ne	
Indoor unit model name			information relates to. Indicated values should relate to one			
Outdoor unit model name SRC35ZS-W2		heating season at a time. Include at least the heating season 'Average'.				
Function(indicate if present)			Average(mandatory)	Yes		
cooling	Yes		Warmer(if designated)	Yes		
heating	Yes		Colder(if designated)	No		
Item	symbol value	unit	Item	symbol	value	class
Design load	-		Seasonal efficiency and energy efficiency cla	ss		
cooling	Pdesignc 3.50	kW	cooling	SEER	8.10	A++
heating / Average	Pdesignh 2.90	kW	heating / Average	SCOP/A	4.70	A++
heating / Warmer	Pdesignh 3.80	kW	heating / Warmer	SCOP/W	5.90	A+++
heating / Colder	Pdesignh -	kW	heating / Colder	SCOP/C	-	-
						unit
Declared capacity at outdoor temperature	Tdesignh		Back up heating capacity at outdoor tempera	ture Tdesignh	n	=
heating / Average (-10°C)	Pdc 2.90	kW	heating / Average (-10°C)	elbu	0	kW
heating / Warmer (2°C)	Pdc 3.80	kW	heating / Warmer (2°C)	elbu	-	kW
heating / Colder (-22°C)	Pdc -	kW	heating / Colder (-22°C)	elbu	-	kW
Declared capacity for cooling, at indoor temperature 27(19)°C and Declared energy efficiency ratio, at indoor temperature 27(19)°C and						
outdoor temperature Tj		_	outdoor temperature Tj			7
Tj=35°C	Pdc 3.50	kW	Tj=35°C	EERd	4.27	
Tj=30°C	Pdc 2.60	kW	Tj=30°C	EERd	6.47	
Tj=25°C	Pdc 1.60	kW	Tj=25°C	EERd	10.10	
Tj=20°C	Pdc 1.20	kW	Tj=20°C	EERd	18.90	
B 1 1 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2					 	
Declared capacity for heating / Average season, at indoor Declared coefficient of performance / Average season, at indoor						
temperature 20°C and outdoor temperature		¬	temperature 20°C and outdoor temperature			7
Tj=-7°C	Pdh 2.50	kW	Tj=-7°C	COPd	2.86	⊣ -
Tj=2°C	Pdh 1.60	kW	Tj=2°C	COPd	4.90	4-
Tj=7°C	Pdh 1.00	kW	Tj=7°C	COPd	5.70	4-
Tj=12°C	Pdh 1.00	kW	Tj=12°C	COPd	7.30	_
Tj=bivalent temperature	Pdh 2.90	kW	Tj=bivalent temperature	COPd	2.60	
Tj=operating limit	Pdh 2.90	kW	Tj=operating limit	COPd	2.60	-
To 1 1 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2						
Declared capacity for heating / Warmer se			Declared coefficient of performance / Warme		indoor	
temperature 20°C and outdoor temperature		¬	temperature 20°C and outdoor temperature			7
Tj=2°C	Pdh 3.80	kW	Tj=2°C	COPd	2.99	4-
Tj=7°C	Pdh 2.40	kW	Tj=7°C	COPd	5.36	
Tj=12°C	Pdh 1.00	kW	Tj=12°C	COPd	7.30	
Tj=bivalent temperature	Pdh 3.80	kW	Tj=bivalent temperature	COPd	2.99	
Tj=operating limit	Pdh 3.80	kW	Tj=operating limit	COPd	2.99	-
Declared capacity for heating / Colder sea			Declared coefficient of performance / Colder		idoor	
temperature 20°C and outdoor temperature		¬	temperature 20°C and outdoor temperature			7
Tj=-7°C	Pdh <u>-</u>	kW	Tj=-7°C	COPd	-	4-
Tj=2°C	Pdh	kW	Tj=2°C	COPd	-	
Tj=7°C	Pdh <u>-</u>	kW	Tj=7°C	COPd	-	
Tj=12°C	Pdh	kW	Tj=12°C	COPd	-	
Tj=bivalent temperature	Pdh	kW	Tj=bivalent temperature	COPd	-	
Tj=operating limit	Pdh -	kW	Tj=operating limit	COPd	-	
Tj=−15°C	Pdh -	kW	Tj=−15°C	COPd	-	-
Bivalent temperature			Operating limit temperature			70-
heating / Average	Tbiv <u>-10</u>	°C	heating / Average	Tol	-10	_°C
heating / Warmer	Tbiv 2	°C	heating / Warmer	Tol	2	_°C
heating / Colder	Tbiv -	°C	heating / Colder	Tol		°C
0 11 11 11						
Cycling interval capacity			Cycling interval efficiency	FFD		7
for cooling	Pcycc	kW	for cooling	EERcyc	<u> </u>	⊣ _
for heating	Pcych -	kW	for heating	COPcyc	-	-
D 111 (C 1			D 1.: (C : :			
Degradation coefficient	0.1	_	Degradation coefficient	0.11	0.05	7
cooling	Cdc 0.25		heating	Cdh	0.25	<u> </u>
Florida and the state of the st	11		[[A			
Electric power input in power modes other		w	Annual electricity consumption	0	450	kWh/a
off mode	Poff <u>7</u>		cooling	Qce	152	
standby mode	Psb 7	w	heating / Average	Qhe	864	kWh/a
thermostat-off mode	Pto(cooling) 12	W	heating / Warmer	Qhe	902	kWh/a
annulus and least on the state	Pto(heating) 15	w	heating / colder	Qhe	-	kWh/a
crankcase heater mode	Pck 0	W				
Out of the control Vindicate and of those patients						
Capacity control(indicate one of three opti	ons)		Other items	Loren	E4	Jad(*)
			Sound power level(indoor)	Lwa	51 63	dB(A)
	No		Sound power level(outdoor)	Lwa		dB(A)
fixed	No No		Global warming potential	GWP	675	kgCO2eq.
staged	No Yos		Rated air flow(indoor)	_	552	m3/h
variable	Yes		Rated air flow(outdoor)	_	1890	m3/h
Contact details for obtaining	Mama and addition	f +bo	human an of its outleasterd service set of the			
Contact details for obtaining		rine manufact	turer or of its authorised representative.			
	SERVICES B.V.	1101 OM A	stordom Nothorlando			
	bergweg 238, Luna ArenA					
P.O.B0	x 23393 1100 DW Amstero	aan, metrieriari	us .			