Information to identify the model(s) to		relates to:	If function includes heating: Indicate the			
Indoor unit model name FDE60VH			information relates to. Indicated values should relate to one			
Outdoor unit model name	SRC60ZSX-	W3	heating season at a time. Include at lea	st the heating seas	on 'Average'.	
			_ 			
Function(indicate if present)			Average(mandatory)		Yes	
cooling	Yes		Warmer(if designated)	No		
heating	Yes		Colder(if designated)	No		
Item	symbol va	ılue unit	Item	symbol	value class	
Design load	_		Seasonal efficiency and energy efficien			
cooling	Pdesignc	5.6 kW	cooling	SEER	6.72 A++	
heating / Average	Pdesignh	4.5 kW	heating / Average	SCOP/A	4.41 A+	
heating / Warmer	Pdesignh	- kW	heating / Warmer	SCOP/W		
heating / Colder	Pdesignh	- kW	heating / Colder	SCOP/C		
					unit	
Declared capacity at outdoor tempera	ture Tdesignh		Back up heating capacity at outdoor te	mperature Tdesignh	n	
heating / Average (-10°C)	Pdc	4.5 kW	heating / Average (-10°C)	elbu	0 kW	
heating / Warmer (2°C)	Pdc	- kW	heating / Warmer (2°C)	elbu	- kW	
heating / Colder (-22°C)	Pdc	- kW	heating / Colder (-22°C)	elbu	- kW	
Troubling / Gordon (22 G/		1,,,,	industry outside (22 o)		1	
Declared capacity for cooling, at indoo	r temperature 27(19)°C	and	Declared energy efficiency ratio, at inde	oor temperature 27	(19)°C and	
outdoor temperature Ti			outdoor temperature Ti		,	
Tj=35°C	Pdc	5.60 kW	Ti=35°C	EERd	3.71 -	
Tj=30°C	Pdc	4.13 kW	T _i =30°C	EERd	5.56 -	
Tj=30 C Tj=25°C	Pdc	2.65 kW	Ti=25°C	EERd	8.94 -	
Tj=20°C	Pdc	1.50 kW	Tj=20°C	EERd	11.70 -	
1j=20 C	Pac	1.50 JKW	[1]=20 C	EERO	11.70 -	
Dodared capacity for hasting / A			Declared coefficient of performance / /	Avorage coess:	indoor	
Declared capacity for heating / Average					IIIuuur	
temperature 20°C and outdoor temper	,	0.00	temperature 20°C and outdoor tempera	•	0.07	
Tj=-7°C	Pdh	3.98 kW	Tj=-7°C	COPd	3.07	
Tj=2°C	Pdh	2.42 kW	Tj=2°C	COPd	4.34 -	
Tj=7°C	Pdh	1.56 kW	Tj=7°C	COPd	5.58 -	
Tj=12°C	Pdh	1.00 kW	Tj=12°C	COPd	5.94 -	
Tj=bivalent temperature	Pdh	4.50 kW	Tj=bivalent temperature	COPd	2.66 -	
Tj=operating limit	Pdh	3.30 kW	Tj=operating limit	COPd	2.30 -	
Declared capacity for heating / Warme	r season, at indoor		Declared coefficient of performance / Warmer season, at indoor			
temperature 20°C and outdoor temper	ature Tj		temperature 20°C and outdoor tempera	iture Tj		
Tj=2°C	Pdh	- kW	Tj=2°C	COPd		
Tj=7°C	Pdh	- kW	Tj=7°C	COPd		
Tj=12°C	Pdh	- kW	Ti=12°C	COPd		
Tj=bivalent temperature	Pdh	- kW	Tj=bivalent temperature	COPd		
Tj=operating limit	Pdh	- kW	Tj=operating limit	COPd		
Declared capacity for heating / Colder temperature 20°C and outdoor temper Tj=-7°C	ature Tj Pdh	- kW	Declared coefficient of performance / 0 temperature 20°C and outdoor tempera Tj=-7°C	ature Tj COPd		
Tj=2°C	Pdh	- kW	Tj=2°C	COPd		
Tj=7°C	Pdh	- kW	Tj=7°C	COPd		
Tj=12°C	Pdh	- kW	Tj=12°C	COPd		
Tj=bivalent temperature	Pdh	kW	Tj=bivalent temperature	COPd		
Tj=operating limit	Pdh	- kW	Tj=operating limit	COPd		
Tj=−15°C	Pdh	- kW		COPd		
Bivalent temperature			Operating limit temperature			
heating / Average	Tbiv	<u>-10</u> ℃	heating / Average	Tol	-20 ℃	
heating / Warmer	Tbiv	- ℃	heating / Warmer	Tol	°C	
heating / Colder	Tbiv	- °C	heating / Colder	Tol	- ℃	
Cycling interval capacity			Cycling interval efficiency			
for cooling	Pcycc	- kW	for cooling	EERcyc		
for heating	Pcych	- kW	for heating	COPcyc	<u> </u>	
Degradation coefficient			Degradation coefficient			
cooling	Cdc	0.25 -	heating	Cdh	0.25 -	
Electric power input in power modes of	ther than 'active mode'		Annual electricity consumption			
off mode	Poff	13 W	cooling	Qce	292 kWh/a	
standby mode	Psb	13 W	heating / Average	Qhe	1430 kWh/a	
thermostat-off mode	Pto(cooling)	20 W	heating / Warmer	Qhe	- kWh/a	
	Pto(heating)	35 W	heating / colder	Qhe	- kWh/a	
crankcase heater mode	Pck	0 W			1,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	
	1 01	· ["				
Capacity control(indicate one of three	ontions)		Other items			
Suparity Control(indicate one of three	options/		Sound power level(indoor)	Lwa	60 dB(A)	
			Sound power level(outdoor)	Lwa	65 dB(A)	
fixed	No			GWP	675 kgCO2eq.	
fixed	No		Global warming potential Rated air flow(indoor)	GWP	1200 kgCO2eq.	
staged	Yes			_	2490 m3/h	
variable	162		Rated air flow(outdoor)			
Company deposits from the control of	M	luana af ili	akaman an af ika sasika da sa da sa da sa			
Contact details for obtaining		iress or the manufa	acturer or of its authorised representative.			
more information MHIAE SERVICES B.V.						
Herikerbergweg 238, Luna ArenA, 1101 CM Amsterdam, Netherlands						
P.O.Box 23393 1100 DW Amsterdam, Netherlands						