

Außengerät		BXM50A5V1B	
Innengerät		FVXM50A3V1B	
<b>Function</b>		<b>Heating season</b>	
Kühlen	Ja	Average (mandatory)	Ja
Heizen	Ja	Warmer (if designated)	Ja
		Colder (if designated)	Nein
<b>Element</b>	<b>Symbol</b>	<b>Wert</b>	<b>Gerät</b>
<b>Design Load</b>			
Kühlen	P <sub>designc</sub>	5.00	kW
heating / Average	P <sub>designh</sub>	4.10	kW
heating / Warmer	P <sub>designh</sub>	2.21	kW
heating / Colder	P <sub>designh</sub>		kW
<b>Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur T<sub>J</sub></b>		<b>Deklarierte Leistung* für Kühlen, bei Innentemperatur 27 (19) °C und Außentemperatur T<sub>J</sub></b>	
T <sub>J</sub> = 35 °C	P <sub>dc</sub>	5.00	kW
T <sub>J</sub> = 30 °C	P <sub>dc</sub>	3.69	kW
T <sub>J</sub> = 25 °C	P <sub>dc</sub>	2.37	kW
T <sub>J</sub> = 20 °C	P <sub>dc</sub>	2.20	kW
T <sub>J</sub> = 35 °C	EER <sub>d</sub>	3.81	-
T <sub>J</sub> = 30 °C	EER <sub>d</sub>	5.49	-
T <sub>J</sub> = 25 °C	EER <sub>d</sub>	8.59	-
T <sub>J</sub> = 20 °C	EER <sub>d</sub>	12.51	-
<b>Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature T<sub>J</sub></b>		<b>Declared coefficient of performance* / Average season , at indoor temperature 20 °C and outdoor temperature T<sub>J</sub></b>	
T <sub>J</sub> = -7 °C	P <sub>dh</sub>	3.63	kW
T <sub>J</sub> = 2 °C	P <sub>dh</sub>	2.21	kW
T <sub>J</sub> = 7 °C	P <sub>dh</sub>	1.67	kW
T <sub>J</sub> = 12 °C	P <sub>dh</sub>	1.84	kW
T <sub>J</sub> = Bivalent temperature	P <sub>dh</sub>	3.63	kW
T <sub>J</sub> = operating limit	P <sub>dh</sub>	3.49	kW
T <sub>J</sub> = -7 °C	COP <sub>d</sub>	3.16	-
T <sub>J</sub> = 2 °C	COP <sub>d</sub>	4.45	-
T <sub>J</sub> = 7 °C	COP <sub>d</sub>	5.15	-
T <sub>J</sub> = 12 °C	COP <sub>d</sub>	5.98	-
T <sub>J</sub> = Bivalent temperature	COP <sub>d</sub>	3.16	-
T <sub>J</sub> = operating limit	COP <sub>d</sub>	1.82	-
<b>Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature T<sub>J</sub></b>		<b>Declared coefficient of performance* / Warmer season , at indoor temperature 20 °C and outdoor temperature T<sub>J</sub></b>	
T <sub>J</sub> = 2 °C	P <sub>dh</sub>	2.21	kW
T <sub>J</sub> = 7 °C	P <sub>dh</sub>	1.67	kW
T <sub>J</sub> = 12 °C	P <sub>dh</sub>	1.84	kW
T <sub>J</sub> = Bivalent temperature	P <sub>dh</sub>	2.21	kW
T <sub>J</sub> = operating limit	P <sub>dh</sub>	3.49	kW
T <sub>J</sub> = 2 °C	COP <sub>d</sub>	4.45	-
T <sub>J</sub> = 7 °C	COP <sub>d</sub>	5.15	-
T <sub>J</sub> = 12 °C	COP <sub>d</sub>	5.98	-
T <sub>J</sub> = Bivalent temperature	COP <sub>d</sub>	4.45	-
T <sub>J</sub> = operating limit	COP <sub>d</sub>	1.82	-
<b>Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature T<sub>J</sub></b>		<b>Declared coefficient of performance* / Colder season , at indoor temperature 20 °C and outdoor temperature T<sub>J</sub></b>	
T <sub>J</sub> = -7 °C	P <sub>dh</sub>		kW
T <sub>J</sub> = 2 °C	P <sub>dh</sub>		kW
T <sub>J</sub> = 7 °C	P <sub>dh</sub>		kW
T <sub>J</sub> = 12 °C	P <sub>dh</sub>		kW
T <sub>J</sub> = Bivalent temperature	P <sub>dh</sub>		kW
T <sub>J</sub> = operating limit	P <sub>dh</sub>		kW
T <sub>J</sub> = -15 °C	P <sub>dh</sub>		kW
T <sub>J</sub> = -7 °C	COP <sub>d</sub>		-
T <sub>J</sub> = 2 °C	COP <sub>d</sub>		-
T <sub>J</sub> = 7 °C	COP <sub>d</sub>		-
T <sub>J</sub> = 12 °C	COP <sub>d</sub>		-
T <sub>J</sub> = Bivalent temperature	COP <sub>d</sub>		-
T <sub>J</sub> = operating limit	COP <sub>d</sub>		-
T <sub>J</sub> = -15 °C	COP <sub>d</sub>		-
<b>Bivalent temperature</b>		<b>operating limit</b>	
heating / Average	T <sub>biv</sub>	-7	°C
heating / Warmer	T <sub>biv</sub>	2	°C
heating / Colder	T <sub>biv</sub>		°C
heating / Average	T <sub>ol</sub>	-15	°C
heating / Warmer	T <sub>ol</sub>	-15	°C
heating / Colder	T <sub>ol</sub>		°C
<b>Cycling Interval capacity</b>		<b>Cycling Interval efficiency</b>	
for cooling	P <sub>cycc</sub>		kW
for heating	P <sub>cych</sub>		kW
Degradation co-efficient cooling**	C <sub>dc</sub>	0.25	-
for cooling	EER <sub>cycc</sub>		-
for heating	COP <sub>cycc</sub>		-
Degradation co-efficient cooling**	C <sub>dh</sub>	0.25	-
<b>Electric power input in power models other than 'active mode'</b>		<b>Annual electricity consumption</b>	
Off mode	P <sub>off</sub>	0.001	kW
Standby mode	P <sub>sb</sub>	0.001	kW
Thermostat-off mode	P <sub>TO</sub>	0	kW
Crankcase heater mode	P <sub>CK</sub>	0	kW
Kühlen	Q <sub>CE</sub>	240	kWh/a
heating / Average	Q <sub>HE</sub>	1,330	kWh/a
heating / Warmer	Q <sub>HE</sub>	638	kWh/a
heating / Colder	Q <sub>HE</sub>		kWh/a
<b>Capacity control</b>		<b>Other Items</b>	
Fest	N	Sound power level (indoor/outdoor)	L <sub>WA</sub> 61.0 / 62.0 db(A)
Gestaffelt	N	Global warming potential	GWP 675 kgCO <sub>2</sub> eq.
Variable	N	Rated air flow (indoor/outdoor)	- 11.6 / 58.0 m <sup>3</sup> /min
<b>Contact details for obtaining more information</b>		Dalkin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium	

\* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

\*\* if default C<sub>d</sub> = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.