Information to identify the model(s) to	which the information relates to:	If function includes heating: Indicate the I	heating season the
Indoor unit model name  SRK35ZTL-W		information relates to. Indicated values should relate to one	
Outdoor unit model name			
	10.1000=1=11		
Function(indicate if present)		Average(mandatory)	Yes
cooling	Yes	Warmer(if designated)	Yes
heating	Yes	Colder(if designated)	No
_	·		•
Item	symbol value unit	Item	symbol value class
Design load		Seasonal efficiency and energy efficiency	/ class
cooling	Pdesignc 3.5 kW	cooling	SEER <b>6.50</b> A++
heating / Average	Pdesignh 2.8 kW	heating / Average	SCOP/A <b>4.70</b> A++
heating / Warmer	Pdesignh <b>3.9</b> kW	heating / Warmer	SCOP/W <b>5.80</b> A+++
heating / Colder	Pdesignh - kW	heating / Colder	SCOP/C
			unit
Declared capacity at outdoor temperat	ure Tdesignh	Back up heating capacity at outdoor temp	perature Tdesignh
heating / Average (-10°C)	Pdc 2.8 kW	heating / Average (-10°C)	elbu <b>0</b> kW
heating / Warmer (2°C)	Pdc <b>3.9</b> kW	heating / Warmer (2°C)	elbu <b>0</b> kW
heating / Colder (-22°C)	Pdc - kW	heating / Colder (-22°C)	elbu - kW
Declared capacity for cooling, at indoor temperature 27(19)°C and Declared energy efficiency ratio, at indoor temperature 27(19)°C and			
outdoor temperature Tj		outdoor temperature Tj	
Tj=35°C	Pdc <b>3.50</b> kW	Tj=35°C	EERd <b>3.33</b> -
Tj=30°C	Pdc <b>2.58</b> kW	Tj=30°C	EERd <b>5.32</b> -
Tj=25°C	Pdc <b>1.66</b> kW	Tj=25°C	EERd <b>8.40</b> -
Tj=20°C	Pdc <b>1.08</b> kW	Tj=20°C	EERd <b>12.20</b> -
Declared capacity for heating / Average season, at indoor  Declared coefficient of performance / Average season, at indoor			
temperature 20°C and outdoor tempera	ture Tj	temperature 20°C and outdoor temperatu	ıre Tj
Tj=-7°C	Pdh <b>2.48</b> kW	Tj=−7°C	COPd <b>3.25</b> -
Tj=2°C	Pdh <b>1.51</b> kW	T <sub>i</sub> =2°C	COPd <b>4.67</b> -
Tj=7°C	Pdh <b>1.04</b> kW	Tj=7°C	COPd <b>5.75</b> -
Tj=12°C	Pdh <b>1.22</b> kW	Tj=12°C	COPd <b>7.43</b> -
Tj=bivalent temperature	Pdh <b>2.80</b> kW	Tj=bivalent temperature	COPd <b>2.53</b> -
Tj=operating limit	Pdh <b>2.80</b> kW	Tj=operating limit	COPd <b>2.53</b> -
IJ-operating minit	1 dil   2.00   KYY	ij-operacing innic	2.33
Declared capacity for heating / Warmer	r season, at indoor	Declared coefficient of performance / Wa	armer season, at indoor
temperature 20°C and outdoor tempera		temperature 20°C and outdoor temperature	
Tj=2°C	Pdh <b>3.90</b> kW	Tj=2°C	COPd <b>2.85</b> -
Tj=7°C	Pdh <b>2.51</b> kW	Tj=7℃	COPd <b>5.08</b> -
Tj=12°C	Pdh 1.22 kW	Ti=12℃	COPd 7.45 -
-	Pdh 3.90 kW	113	COPd 2.85 -
Tj=bivalent temperature	Pdh <b>3.90</b> kW	Tj=bivalent temperature	COPd 2.85 -
Tj=operating limit	Fun 3.90 KW	Tj=operating limit	COP4   <b>2.65</b>
Declared capacity for heating / Colder	socon at indoor	Declared coefficient of performance / Co	older coocen et indeer
temperature 20°C and outdoor tempera			
		temperature 20°C and outdoor temperature	
Tj=-7°C	Pdh - kW	Tj=−7°C	COPd <u>-</u> -
Tj=2°C	Pdh - kW	Tj=2°C	COPd
Tj=7°C	PdhkW	Tj=7°C	COPd <u>-</u> -
Tj=12°C	PdhkW	Tj=12°C	COPd <u>-</u> -
Tj=bivalent temperature	PdhkW	Tj=bivalent temperature	COPd <u>-</u> –
Tj=operating limit	PdhkW	Tj=operating limit	COPd <u>-</u> –
Tj=−15°C	Pdh - kW	Tj=-15°C	COPd
Bivalent temperature		Operating limit temperature	- ·
heating / Average	Tbiv <b>-10</b>	heating / Average	Tol <u>-10</u> ℃
heating / Warmer	Tbiv <b>2</b> °C	heating / Warmer	Tol <b>2</b> ℃
heating / Colder	Tbiv - °C	heating / Colder	Tol - ℃
Cycling interval capacity	<del></del>	Cycling interval efficiency	
for cooling	Pcycc - kW	for cooling	EERcyc
for heating	Pcych - kW	for heating	COPcyc
Degradation coefficient		Degradation coefficient	0.11
cooling	Cdc <b>0.25</b> -	heating	Cdh <b>0.25</b> -
El		A 1 1 2 2 2 2	
Electric power input in power modes of		Annual electricity consumption	
off mode	Poff <u>8</u> W	cooling	Qce 189 kWh/a
standby mode	Psb <b>8</b> W	heating / Average	Qhe <b>835</b> kWh/a
thermostat-off mode	Pto(cooling) 6 W	heating / Warmer	Qhe <b>943</b> kWh/a
	Pto(heating) 14 W	heating / colder	Qhe - kWh/a
crankcase heater mode	Pck 0 W		
		Tr	
Capacity control(indicate one of three	options)	Other items	<del></del>
		Sound power level(indoor)	Lwa <b>56</b> dB(A)
		Sound power level(outdoor)	Lwa <b>61</b> dB(A)
fixed	No	Global warming potential	GWP <b>675</b> kgCO2eq.
staged	No	Rated air flow(indoor)	- <b>624</b> m3/h
variable	Yes	Rated air flow(outdoor)	- <b>1524</b> m3/h
	•		
Contact details for obtaining	Name and address of the manu	facturer or of its authorised representative.	
	IAE SERVICES B.V.	-p	
	ikerbergweg 238, Luna ArenA, 1101 CM	Amsterdam, Netherlands	
	Box 23393 1100 DW Amsterdam, Nethe		
	,		