

Model(s) : FDC125VSA / FDT125VH

Outdoor side heat exchanger of air conditioner : air

Indoor side heat exchanger of air conditioner : air

Type : vapour compression

if applicable : electric motor

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated cooling capacity	Prated,c	12.5	kW	Seasonal space cooling energy efficiency ηs,c		258.0	%
Declared cooling capacity for part load at given outdoor temperatures Tj and indoor 27°C/19°C(dry/wet bulb)				Declared energy efficiency ratio or gas utilization efficiency / auxiliary energy factor for part load at given outdoor temperatures Tj			
Tj=+35°C	Pdc	12.5	kW	Tj=+35°C	EERd or GUEc,bin / AEFc,bin	309.0	%
Tj=+30°C	Pdc	9.2	kW	Tj=+30°C	EERd or GUEc,bin / AEFc,bin	475.0	%
Tj=+25°C	Pdc	5.9	kW	Tj=+25°C	EERd or GUEc,bin / AEFc,bin	775.0	%
Tj=+20°C	Pdc	3.5	kW	Tj=+20°C	EERd or GUEc,bin / AEFc,bin	1270.0	%
Degradation coefficient for air conditioners**	Cdc	0.25	-				
Power consumption in other than 'active mode'							
Off mode	P <sub>OFF</sub>	0.008	kW	Crankcase heater mode	P <sub>CK</sub>	0.008	kW
Thermostat-off mode	P <sub>TO</sub>	0.020	kW	Standby mode	P <sub>SB</sub>	0.008	kW
Other items				For air-to-air air conditioner: air flow-rate,outdoor measured			
Capacity control		variable				4500	m <sup>3</sup> /h
Sound power level, outdoor	L <sub>WA</sub>	71.0	dB				
If engine driven: Emissions of nitrogen oxides	NOx ***	-	mg/kWh fuel input GCV				
GWP of the refrigerant		2088	kg CO <sub>2eq</sub> (100years)				

Contact details Mitsubishi heavy industries thermal systems,LTD

\*\* If Cdc is not determined by measurement then the default degradation coefficient air conditioners shall be 0,25.

\*\*\* from 26 September 2018

Where information relates to multi-split air conditioners,the test result and performance data be obtained on the basis of the performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer.

Information to identify the model(s) to which the information relates : **FDC125VSA / FDT125VH**

Outdoor side heat exchanger of heat pump : **air**

Indoor side heat exchanger of heat pump : **air**

Indication if the heater is equipped with a supplementary heater : **No**

if applicable : **electric motor**

Parameters shall be declared for the average heating season , parameters for the warmer and colder heating seasons are optional.

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heating capacity	Prated,h	<b>14.0</b>	kW	Seasonal space heating energy efficiency ηs,h		<b>172.1</b>	%
Declared heating capacity for part load at indoor temperature 20°C and outdoor temperature Tj				Declared coefficient of performance or gas utilization efficiency / auxiliary energy factor for part load at given outdoor temperatures Tj			
Tj=-7°C	Pdh	<b>8.7</b>	kW	Tj=-7°C	COPd or GUEh,bin / AEFh,bin	<b>310.0</b>	%
Tj=+2°C	Pdh	<b>5.3</b>	kW	Tj=+2°C	COPd or GUEh,bin / AEFh,bin	<b>415.0</b>	%
Tj=+7°C	Pdh	<b>3.4</b>	kW	Tj=+7°C	COPd or GUEh,bin / AEFh,bin	<b>579.0</b>	%
Tj=+12°C	Pdh	<b>2.7</b>	kW	Tj=+12°C	COPd or GUEh,bin / AEFh,bin	<b>643.0</b>	%
Tbiv=bivalent temperature	Pdh	<b>9.8</b>	kW	Tbiv=bivalent temperature	COPd or GUEh,bin / AEFh,bin	<b>257.0</b>	%
TOL=operation limit	Pdh	<b>7.7</b>	kW	TOL=operation limit	COPd or GUEh,bin / AEFh,bin	<b>235.0</b>	%
For air-to-water heat pumps : Tj=-15°C (if TOL < -20°C)	Pdh	<b>-</b>	kW	For air-to-water heat pumps:Tj=-15°C (if TOL < -20°C)	COPd or GUEh,bin / AEFh,bin	<b>-</b>	%
Bivalent temperature	Tbiv	<b>-10.0</b>	°C	For water-to-air heat pumps:Operation limit Tol temperature		<b>-</b>	°C
Degradation coefficient heat pumps**	Cdh	<b>0.25</b>	-				
Power consumption in modes other than 'active mode'				Supplementary heater back-up heating capacity			
Off mode	P <sub>OFF</sub>	<b>0.008</b>	kW		elbu	<b>-</b>	kW
Thermostat-off mode	P <sub>TO</sub>	<b>0.035</b>	kW	Type of energy input	P <sub>SB</sub>	<b>0.008</b>	kW
Crankcase heater mode	P <sub>CK</sub>	<b>0.008</b>	kW	Standby mode			
Other items				For air-to-air heat pumps: air flow-rate,outdoor measured			
Capacity control		<b>variable</b>				<b>4380</b>	m3/h
Sound power level, outdoor measured	L <sub>WA</sub>	<b>71.0</b>	dB	For water-/brine-to-air heat pumps : Rated brine or water flow-rate, outdoor side heat exchanger		<b>-</b>	m3/h
Emissions of nitrogen oxides(if applicable)	NOx ***	<b>-</b>	mg/kWh fuel input GCV				
GWP of the refrigerant		<b>2088</b>	kg CO <sub>2eq</sub> (100years)				

Contact details | **Mitsubishi heavy industries thermal systems,LTD**

\*\* If Cdh is not determined by measurement then the default degradation coefficient air conditioners shall be 0,25.

\*\*\* from 26 September 2018

Where information relates to multi-split air conditioners,the test result and performance data be obtained on the basis of the performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer.