| Information to identify the model(s) to | which the information relates to: | If function includes heating: Indicate the he | eating season th | ie. |
|---|--|--|---------------------|---------------------------|
| Indoor unit model name SRK25ZSX-WFT x 2 units | | information relates to. Indicated values should relate to one | | |
| Outdoor unit model name | SCM40ZS-W | heating season at a time. Include at least the heating season 'Average'. | | |
| | | _ | | |
| Function(indicate if present) | | Average(mandatory) | Yes | |
| cooling | Yes | Warmer(if designated) | Yes | |
| heating | Yes | Colder(if designated) | No | |
| | · | | | |
| Item | symbol value unit | Item | symbol | value class |
| Design load | | Seasonal efficiency and energy efficiency of | class | |
| cooling | Pdesignc 4.00 kW | cooling | SEER | 9.10 A+++ |
| heating / Average | Pdesignh 4.10 kW | heating / Average | SCOP/A | 4.70 A++ |
| heating / Warmer | Pdesignh 5.70 kW | heating / Warmer | SCOP/W | 6.40 A+++ |
| heating / Colder | Pdesignh - kW | heating / Colder | SCOP/C | |
| | | | | unit |
| Declared capacity at outdoor temperat | ture Tdesignh | Back up heating capacity at outdoor temper | erature Tdesignh | 1 |
| heating / Average (-10°C) | Pdc 4.10 kW | heating / Average (-10°C) | elbu | 0 kW |
| heating / Warmer (2°C) | Pdc 5.70 kW | heating / Warmer (2°C) | elbu | 0 kW |
| heating / Colder (-22°C) | Pdc - kW | heating / Colder (-22°C) | elbu | - kW |
| | | 1 | | |
| Declared capacity for cooling, at indoor temperature 27(19)°C and Declared energy efficiency ratio, at indoor temperature 27(19)°C and | | | | |
| outdoor temperature Tj | | outdoor temperature Tj | | |
| Tj=35°C | Pdc <u>4.00</u> kW | Tj=35°C | EERd | 5.15 |
| Tj=30°C | Pdc 2.95 kW | Tj=30°C | EERd | 7.50 - |
| Tj=25°C | Pdc 2.25 kW | Tj=25°C | EERd | 12.65 - |
| Tj=20°C | Pdc 2.30 kW | Tj=20°C | EERd | 17.60 - |
| | | 1 = | | |
| Declared capacity for heating / Average season, at indoor Declared coefficient of performance / Average season, at indoor | | | | |
| temperature 20°C and outdoor temper | | temperature 20°C and outdoor temperature | | |
| Tj=-7°C | Pdh 3.65 kW | Tj=-7°C | COPd | 3.20 - |
| Tj=2°C | Pdh 2.15 kW | Tj=2°C | COPd | 4.60 |
| Tj=7°C | Pdh 1.40 kW | Tj=7°C | COPd | 5.90 - |
| Tj=12°C | Pdh 1.50 kW | Tj=12°C | COPd | 7.85 |
| Tj=bivalent temperature | Pdh 4.10 kW | Tj=bivalent temperature | COPd | 2.60 - |
| Tj=operating limit | Pdh 3.60 kW | Tj=operating limit | COPd | 2.40 - |
| | | 1 | | |
| Declared capacity for heating / Warme | | Declared coefficient of performance / War | | ndoor |
| temperature 20°C and outdoor temper | | temperature 20°C and outdoor temperature | | |
| Tj=2°C | Pdh 5.70 kW | Tj=2°C | COPd | 3.40 - |
| Tj=7°C | Pdh 3.70 kW | Tj=7°C | COPd | 5.90 - |
| Tj=12°C | Pdh 1.50 kW | Tj=12°C | COPd | 7.85 - |
| Tj=bivalent temperature | Pdh 5.70 kW | Tj=bivalent temperature | COPd | 3.40 - |
| Tj=operating limit | Pdh 3.60 kW | Tj=operating limit | COPd | 2.40 - |
| | | 1 | | |
| Declared capacity for heating / Colder | | Declared coefficient of performance / Cold | | door |
| temperature 20°C and outdoor temper | | temperature 20°C and outdoor temperature | | |
| Tj=-7°C | PdhkW | Tj=-7°C | COPd | |
| Tj=2°C | Pdh <u>-</u> kW | Tj=2°C | COPd | |
| Tj=7°C | Pdh <u>-</u> kW | Tj=7°C | COPd | |
| Tj=12°C | Pdh kW | Tj=12°C | COPd | |
| Tj=bivalent temperature | Pdh <u>-</u> kW | Tj=bivalent temperature | COPd | |
| Tj=operating limit | Pdh - kW | Tj=operating limit | COPd | |
| Tj=-15°C | Pdh - kW | Tj=−15°C | COPd | |
| | | | | |
| Bivalent temperature | | Operating limit temperature | | |
| heating / Average | Tbiv <u>-10</u> °C | heating / Average | Tol | <u>-15</u> ℃ |
| heating / Warmer | Tbiv 2 °C | heating / Warmer | Tol | -15 °C |
| heating / Colder | Tbiv - °C | heating / Colder | Tol | - |
| | | | | |
| Cycling interval capacity | <u></u> - | Cycling interval efficiency | | |
| for cooling | Pcycc - kW | for cooling | EERcyc | |
| for heating | Pcych - kW | for heating | COPcyc | |
| | | 1 = | | |
| Degradation coefficient | | Degradation coefficient | | |
| cooling | Cdc 0.25 - | heating | Cdh | 0.25 - |
| | | 1 | | |
| Electric power input in power modes o | | Annual electricity consumption | - | |
| off mode | Poff <u>6</u> W | cooling | Qce | 154 kWh/a |
| standby mode | Psb <u>6</u> W | heating / Average | Qhe | 1222 kWh/a |
| thermostat-off mode | Pto(cooling) 20 W | heating / Warmer | Qhe | 1247 kWh/a |
| | Pto(heating) 30 W | heating / colder | Qhe | - kWh/a |
| crankcase heater mode | Pck 0 W | | | |
| 0 1 1 1 1 | | Tour " | | |
| Capacity control(indicate one of three | options) | Other items | | |
| | | Sound power level(indoor) | Lwa | * 55 dB(A) |
| | | Sound power level(outdoor) | Lwa | 62 dB(A) |
| fixed | No | Global warming potential | GWP | 675 kgCO2eq. |
| staged | No | Rated air flow(indoor) | - | 678 m3/h |
| variable | Yes | Rated air flow(outdoor) | - | 1950 m3/h |
| | | * The sound power level indicated is the highest | value among that of | t connected indoor units. |
| Contact details for obtaining | | cturer or of its authorised representative. | | |
| | HIAE SERVICES B.V. | and the state of t | | |
| | rikerbergweg 238, Luna ArenA, 1101 CM An | | | |
| P.C | O.Box 23393 1100 DW Amsterdam, Netherla | nds | | |
| į J | | | | |