Information to identify the model(s) to w	hich th <u>e information relates to:</u>	If function includes heating: Indicate	the heating season the
Indoor unit model name	SRK25ZSX-WF x 2 units, SRK50ZS	x-wF information relates to. Indicated value	es should relate to one
Outdoor unit model name	SCM71ZS-W	heating season at a time. Include at l	east the heating season 'Average'.
Function(indicate if present)		Average(mandatory)	Yes
cooling	Yes	Warmer(if designated)	Yes
heating	Yes	Colder(if designated)	No
Itom	symbol value unit	Itom	symbol value class
Item Design load	symbol value unit	Item Seasonal efficiency and energy efficiency	
cooling	Pdesignc 7.1 kW	cooling	SEER 7.80 A++
heating / Average	Pdesignh 6.7 kW	heating / Average	SCOP/A 4.30 A+
heating / Warmer	Pdesignh 8.5 kW	heating / Warmer	SCOP/W 5.60 A+++
heating / Colder	Pdesignh - kW	heating / Colder	SCOP/C
Traditing / Gordon	i doorgani jawa	Tracering / Corner	unit
Declared capacity at outdoor temperatu	re Tdesignh	Back up heating capacity at outdoor	temperature Tdesignh
heating / Average (-10°C)	Pdc 6.7 kW	heating / Average (-10°C)	elbu 0 kW
heating / Warmer (2°C)	Pdc 8.5 kW	heating / Warmer (2°C)	elbu 0 kW
heating / Colder (-22°C)	Pdc - kW	heating / Colder (-22°C)	elbu - kW
Declared capacity for cooling, at indoor	temperature 27(19)°C and	Declared energy efficiency ratio, at ir	ndoor temperature 27(19)°C and
outdoor temperature Tj		outdoor temperature Tj	
Tj=35°C	Pdc 7.1 kW	Tj=35°C	EERd 4.67 -
Tj=30°C	Pdc 5.2 kW	Tj=30°C	EERd 6.2 -
Tj=25°C	Pdc 3.3 kW	Tj=25°C	EERd 9.85 -
Tj=20°C	Pdc 3.4 kW	Tj=20°C	EERd 13.9 -
Declared consists for booting / Assume		Declared coefficient of conformation	/ A
Declared capacity for heating / Average temperature 20°C and outdoor temperat		Declared coefficient of performance temperature 20°C and outdoor 20°C and outdoor 20°C and outdoor 20°C and 00°C and 0	
Tj=-7°C	Pdh 6 kW	Ti=-7°C	COPd 3 -
Tj=2°C	Pdh 3.6 kW	Ti=2°C	COPd 3 -
Tj=2 C Tj=7°C	Pdh 2.3 kW	Tj=7°C	COPd 4.3 -
Tj=12°C	Pdh 2.5 kW	Ti=12°C	COPd 5.2 -
Tj=bivalent temperature	Pdh 6.7 kW	Tj=bivalent temperature	COPd 2.3 -
Tj=operating limit	Pdh 6.2 kW	Tj=operating limit	COPd 2.1 -
ij operating innic	1 dii 0.2 KW	ij operacing innic	2.1
Declared capacity for heating / Warmer	season, at indoor	Declared coefficient of performance	/ Warmer season, at indoor
temperature 20°C and outdoor temperat		temperature 20°C and outdoor temperature	
Tj=2°C	Pdh 8.5 kW	Tj=2°C	COPd 2.7 -
Tj=7°C	Pdh 5.4 kW	Tj=7°C	COPd 5.3 -
Tj=12°C	Pdh 2.5 kW	Tj=12°C	COPd 6.7 -
Tj=bivalent temperature	Pdh 8.5 kW	Tj=bivalent temperature	COPd 2.7 -
Tj=operating limit	Pdh 6.2 kW	Tj=operating limit	COPd 2.1 -
Declared capacity for heating / Colder s		Declared coefficient of performance	
temperature 20°C and outdoor temperat		temperature 20°C and outdoor temperature	
Tj=-7°C	PdhkW	Tj=-7°C	COPd <u>-</u> -
Tj=2°C	Pdh - kW	Tj=2°C	COPd
Tj=7°C	Pdh - kW	Tj=7°C	COPd <u>-</u> -
Tj=12°C	Pdh - kW	Tj=12°C	COPd
Tj=bivalent temperature	Pdh - kW	Tj=bivalent temperature	COPd <u>-</u> -
Tj=operating limit	Pdh - kW	Tj=operating limit	COPd <u>-</u> -
Tj=-15°C	Pdh - kW	Tj=-15°C	COPd
Bivalent temperature		Operating limit temperature	
heating / Average	Tbiv -10 °C	heating / Average	Tol -15 °C
heating / Warmer	Tbiv 2 °C	heating / Warmer	Tol -15 °C
heating / Colder	Tbiv - ℃	heating / Colder	Tol - ℃
Cycling interval capacity		Cycling interval efficiency	<u></u>
for cooling	Pcycc - kW	for cooling	EERcyc
for heating	Pcych - kW	for heating	COPcyc
Degradation coefficient	0.1	Degradation coefficient	0.11
cooling	Cdc 0.25 -	heating	Cdh 0.25 -
Electric power input in power modes oth	er than 'active mode'	Annual electricity consumption	
off mode	Poff 9 W	cooling	Qce 319 kWh/a
standby mode	Psb 9 W	heating / Average	Qhe 2181 kWh/a
thermostat-off mode	Pto(cooling) 25 W	heating / Warmer	Qhe 2127 kWh/a
The state of the s	Pto(heating) 35 W	heating / colder	Qhe - kWh/a
crankcase heater mode	Pck 0 W	modeling / coldor	intitity d
	1 - 1		
Capacity control(indicate one of three o	ptions)	Other items	
		Sound power level(indoor)	Lwa * 59 dB(A)
		Sound power level(outdoor)	Lwa 65 dB(A)
fixed	No	Global warming potential	GWP 675 kgCO2eq.
staged	No	Rated air flow(indoor)	- 732 m3/h
variable	Yes	Rated air flow(outdoor)	- 3360 m3/h
		·	ighest value among that of connected indoor units.
Contact details for obtaining		ufacturer or of its authorised representative	e.
	AE SERVICES B.V.		
	kerbergweg 238, Luna ArenA, 1101 CN		
P.O.I	Box 23393 1100 DW Amsterdam, Neth	nerlands	