Information to identify the model(s) to		If function includes heating: Indicate the heating season the		
Indoor unit model name SRK25ZSX-WF, SRK50ZSX-WF information relates to. Indicated values should relate to one				
Outdoor unit model name	SCM60ZS-W	heating season at a time. Include at lea	st the heating seaso	on 'Average'.
		,		
Function(indicate if present)	-	Average(mandatory)	Yes	
cooling	Yes	Warmer(if designated)	Yes	
heating	Yes	Colder(if designated)	No	
Item	symbol value unit	Item		value class
Design load		Seasonal efficiency and energy efficien		
cooling	Pdesignc 6.00 kW	cooling	SEER	8.20 A++
heating / Average	Pdesignh 4.80 kW	heating / Average	SCOP/A	4.70 A++
heating / Warmer	Pdesignh <u>6.40</u> kW	heating / Warmer	SCOP/W	6.40 A+++
heating / Colder	Pdesignh - kW	heating / Colder	SCOP/C	- -
		1		unit
Declared capacity at outdoor temperat		Back up heating capacity at outdoor te	mperature Tdesignh	
heating / Average (-10°C)	Pdc 4.80 kW	heating / Average (-10°C)	elbu	0 kW
heating / Warmer (2°C)	Pdc 6.40 kW	heating / Warmer (2°C)	elbu	0 kW
heating / Colder (-22°C)	Pdc - kW	heating / Colder (-22°C)	elbu	- kW
		1		
Declared capacity for cooling, at indoor	r temperature 27(19)°C and	Declared energy efficiency ratio, at inde	oor temperature 27(19)°C and
outdoor temperature Tj		outdoor temperature Tj		
Tj=35°C	Pdc 6.00 kW	Tj=35°C	EERd	3.85 -
Tj=30°C	Pdc 4.40 kW	Tj=30°C	EERd	6.20 -
Tj=25°C	Pdc 2.80 kW	Tj=25°C	EERd	11.30 -
Tj=20°C	Pdc 2.65 kW	Tj=20°C	EERd	14.60 -
	, == , == , == ,	1		
Declared capacity for heating / Averag	e season, at indoor	Declared coefficient of performance /	Average season, at i	ndoor
temperature 20°C and outdoor tempera		temperature 20°C and outdoor tempera		
Tj=-7°C	Pdh 4.10 kW	Ti=-7°C	COPd	3.25 -
Tj=2°C	Pdh 2.60 kW	T _{i=2} °C	COPd	4.60 -
Tj=7°C	Pdh 1.65 kW		COPd	5.80 -
Tj=12°C	Pdh 1.95 kW		COPd	8.00 -
-		1 1 -	COPd	
Tj=bivalent temperature		Tj=bivalent temperature		2.60
Tj=operating limit	Pdh 4.35 kW	Tj=operating limit	COPd	2.40 -
Dealers I was the feet to all a / Wesser	and the state of t	D I	(4/	
Declared capacity for heating / Warme		Declared coefficient of performance /		ldoor
temperature 20°C and outdoor tempera		temperature 20°C and outdoor tempera		
Tj=2°C	Pdh 6.40 kW	Tj=2°C	COPd	3.10 -
Tj=7°C	Pdh 4.05 kW	Tj=7°C	COPd	5.85
Tj=12°C	Pdh 1.95 kW	Tj=12°C	COPd	8.00 –
Tj=bivalent temperature	Pdh <u>6.40</u> kW	Tj=bivalent temperature	COPd	3.10 –
Tj=operating limit	Pdh 4.35 kW	Tj=operating limit	COPd	2.40 -
		_		
Declared capacity for heating / Colder	season, at indoor	Declared coefficient of performance /	Colder season, at inc	door
temperature 20°C and outdoor temperature	ature Tj	temperature 20°C and outdoor tempera	ature Tj	
Tj=−7°C	Pdh - kW	Tj=−7°C	COPd	
Tj=2°C	Pdh - kW	Tj=2°C	COPd	
Tj=7°C	Pdh - kW	Tj=7°C	COPd	
Tj=12°C	Pdh - kW	Tj=12°C	COPd	
Tj=bivalent temperature	Pdh - kW	Tj=bivalent temperature	COPd	
Tj=operating limit	Pdh - kW	Tj=operating limit	COPd	
Tj=-15°C	Pdh - kW	Tj=-15°C	COPd	
1]- 10 0	1 dii - KW] [1]= 10 0	001 u	
Bivalent temperature		Operating limit temperature		-
heating / Average	Tbiv -10 °C	heating / Average	Tol	-15 ℃
heating / Warmer	Tbiv 2 °C	heating / Warmer	Tol	-15 °C
heating / Colder	Tbiv - °C	heating / Colder	Tol	- 13 c
rieading / Colder	TDIV - C	rieading / Colder	101	C
Cycling interval capacity		Cycling interval efficiency		
for cooling	Pcycc - kW	for cooling	EERcyc	
for heating	Peych - kW	for heating	COPcyc	
Tor nearing	FGYCH - KW	for fleating	COPCyc	<u> </u>
Degradation coefficient		Degradation coefficient		
cooling	Cdc 0.25 -	1 1 =	Cdh	0.25 -
Cooling	Cdc 0.25 -	heating	Can	0.23
Electric power input in power modes of	they then 'estive made'	Annual electricity consumption		
off mode	Poff 6 W	cooling	Qce	256 kWh/a
standby mode	Psb 6 W	heating / Average	Qhe	1431 kWh/a
thermostat-off mode	Pto(cooling) 20 W	heating / Warmer	Qhe	1400 kWh/a
l	Pto(heating) 30 W	heating / colder	Qhe	- kWh/a
crankcase heater mode	Pck 0 W			
		l face of		
Capacity control(indicate one of three	options)	Other items		
		Sound power level(indoor)	Lwa	* 59 dB(A)
		Sound power level(outdoor)	Lwa	63 dB(A)
fixed	No	Global warming potential	GWP	675 kgCO2eq.
staged	No	Rated air flow(indoor)	-	786 m3/h
variable	Yes	Rated air flow(outdoor)	<u> </u>	2460 m3/h
		* The sound power level indicated is the high	est value among that of	connected indoor units.
Contact details for obtaining	Name and address of the manufac	turer or of its authorised representative.		
more information MH	IAE SERVICES B.V.	•		
	rikerbergweg 238, Luna ArenA, 1101 CM Am	sterdam, Netherlands		
	D.Box 23393 1100 DW Amsterdam, Netherlan			