Information to identify the model(s) to wh	nich the information relates to:	If function includes heating: Indicate the	e heating season the
Indoor unit model name SRK50ZSX-WFB		information relates to. Indicated values should relate to one	
Outdoor unit model name	SRC50ZSX-W3	heating season at a time. Include at lea	ist the heating season 'Average'.
Function(indicate if present)	Vac	Average(mandatory)	Yes
cooling	Yes	Warmer(if designated)	Yes
heating	Yes	Colder(if designated)	No
Itom	symbol value unit	Itam	symbol value class
Item Design load	symbol value unit	Item Seasonal efficiency and energy efficien	
cooling	Pdesignc 5 kW	cooling	SEER 8.30 A++
heating / Average	Pdesignh 4.5 kW	heating / Average	SCOP/A 4.70 A++
heating / Warmer	Pdesignh 6 kW	heating / Warmer	SCOP/W 5.89 A+++
heating / Colder	Pdesignh - kW	heating / Colder	SCOP/C
Treating / Golder	i designii kw	ricating / Golder	unit
Declared capacity at outdoor temperatur	e Tdesignh	Back up heating capacity at outdoor te	
heating / Average (-10°C)	Pdc 4.5 kW	heating / Average (-10°C)	elbu 0 kW
heating / Warmer (2°C)	Pdc 6 kW	heating / Warmer (2°C)	elbu 0 kW
heating / Colder (-22°C)	Pdc - kW	heating / Colder (-22°C)	elbu - kW
			· · · · · · · · · · · · · · · · · · ·
Declared capacity for cooling, at indoor temperature 27(19)°C and Declared energy efficiency ratio, at indoor temperature 27(19)°C and			oor temperature 27(19)°C and
outdoor temperature Tj		outdoor temperature Tj	<u></u> _
Tj=35°C	Pdc 5 kW	Tj=35°C	EERd 4.1 -
Tj=30°C	Pdc 3.7 kW	Tj=30°C	EERd 5.9 –
Tj=25°C	Pdc 2.4 kW	Tj=25°C	EERd 9.9 –
Tj=20°C	Pdc 1.5 kW	Tj=20°C	EERd 18.2 -
Declared capacity for heating / Average season, at indoor Declared coefficient of performance / Average season, at indoor			
temperature 20°C and outdoor temperatu		temperature 20°C and outdoor tempera	
Tj=−7°C	Pdh 3.98 kW	Tj=−7°C	COPd <u>3.3</u> -
Tj=2°C	Pdh 2.42 kW	Tj=2°C	COPd 4.64 -
Tj=7°C	Pdh 1.56 kW	Tj=7°C	COPd 5.64 -
Tj=12°C	Pdh 1.06 kW	Tj=12°C	COPd 7.2 -
Tj=bivalent temperature	Pdh 4.5 kW	Tj=bivalent temperature	COPd 2.64 -
Tj=operating limit	Pdh 4.5 kW	Tj=operating limit	COPd 2.64 -
5 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1			
Declared capacity for heating / Warmer		Declared coefficient of performance /	
temperature 20°C and outdoor temperature		temperature 20°C and outdoor tempera	
Tj=2°C	Pdh 6 kW	Tj=2°C	COPd 3.01 -
Tj=7°C	Pdh 3.9 kW	Tj=7°C	COPd <u>5.35</u> -
Tj=12°C	Pdh 1.7 kW	Tj=12°C	COPd 7.2 -
Tj=bivalent temperature	Pdh 6 kW	Tj=bivalent temperature	COPd 3.01 -
Tj=operating limit	Pdh 6 kW	Tj=operating limit	COPd 3.01 -
Declared capacity for heating / Colder so	assan at indoor	Declared coefficient of performance /	Colder seesan at indeer
temperature 20°C and outdoor temperature		temperature 20°C and outdoor tempera	
Ti=-7°C	Pdh - kW	Ti=-7°C	COPd
Tj=2°C			COPd
1]=2	Pdh	1]-2 C Ti=7°C	COPd
Ti=12°C	Pdh - kW	T _i =12°C	COPd
Tj=bivalent temperature	Pdh - kW	Tj=bivalent temperature	COPd
Tj=operating limit	Pdh - kW	Tj=operating limit	COPd
Tj=-15°C	Pdh - kW	Tj=-15°C	COPd
7, 100			
Bivalent temperature		Operating limit temperature	
heating / Average	Tbiv -10 °C	heating / Average	Tol -10 °C
heating / Warmer	Tbiv 2 °C	heating / Warmer	Tol 2 ℃
heating / Colder	Tbiv - °C	heating / Colder	Tol - °C
Cycling interval capacity	<u></u>	Cycling interval efficiency	<u></u> _
for cooling	Pcycc - kW	for cooling	EERcyc
for heating	Pcych - kW	for heating	COPcyc
Degradation coefficient		Degradation coefficient	
cooling	Cdc 0.25 -	heating	Cdh 0.25 -
Electric power input in power modes other		Annual electricity consumption	
off mode	Poff 4 W	cooling	Qce <u>211</u> kWh/a
standby mode	Psb 4 W	heating / Average	Qhe 1341 kWh/a
thermostat-off mode	Pto(cooling) 12 W	heating / Warmer	Qhe 1427 kWh/a
	Pto(heating) 14 W	heating / colder	Qhe - kWh/a
crankcase heater mode	Pck 0 W		
Canada ta a antiqui (finali cata cata)		O4h '4	
Capacity control(indicate one of three or	otions)	Other items	FO 10(A)
		Sound power level(indoor)	Lwa 59 dB(A) Lwa 63 dB(A)
C I	No	Sound power level(outdoor)	
fixed	No	Global warming potential Rated air flow(indoor)	GWP 675 kgCO2eq. - 858 m3/h
staged variable	Yes	Rated air flow(indoor)	- 2340 m3/h
variable	1 103	Itated all How(outdoor)	2370 1113/11
Contact details for obtaining	Name and address of the man	facturer or of its authorised representative.	
_	AE SERVICES B.V.	mastaror or or its authorised representative.	
	kerbergweg 238, Luna ArenA, 1101 CM	Amsterdam Netherlands	
	Box 23393 1100 DW Amsterdam, Nethe		
]	2	-	